

KALBURGI CEMENT PVT. LTD.



Corporate Office: 8-2-626, Reliance Majestic Building, Road No. 10, Banjara Hills, Hyderabad – 500 034, A.P., India. Ph.: +91 40 3006999; Fax: +91 40 3006955 Works: Chatrasala (V), Kharchkhed (Post) - 585 320, Chincholi (Tq.), Gulbarga Dist.; Ph. +91 08472 305999; Fax: +91 08472 305999

TEST CERTIFICATE



PORTLAND POZZOLANA CEMENT(FLY ASH BASED)

Despatched from: 06.08.2018 TO 12.08.2018 Week No: 32

200ptimes 11011			11 CCR 110. 32	
A. PHYSICAL REQUIREMENTS		RESULTS	As per IS 1489 (Part-1) 2015	
Finene	ess:			
a.	Specific Surface (m2/kg)	333	Not less than 300	
b.	Normal Consistency (%)	32.00		
Soundness:				
a.	By Le-Chatelier Method (mm)	0.50	Not more than 10 mm	
b.	By Autoclave (%)	0.031	Not more than 0.8 %	
Setting Time:				
a.	Initial Setting Time (minutes)	170	Not less than 30	
b.	Final Setting Time (minutes)	275	Not more than 600	
Compressive Strength (MPa)				
a.	3 days	24	Not less than 16	
b.	7 days	33	Not less than 22	
C.	28 days	55	Not less than 33	
d.	Drying Shrinkage(%)	Awaited	Not more than 0.15	
e.	Flyash Addition (%)	33.21	Not more than 35	
B. CHEMICAL REQUIREMENTS				
a.	Insoluble Residue (%)	29.89	X+4(100-X)/100; X = % of Flyash	
b.	Magnesia (%)	0.84	Not more than 6.0	
C.	Sulphuric Anhydride (%)	2.26	Not more than 3.5	
d.	Loss on Ignition (%)	1.88	Not more than 5.0	
e.	Temperature During Testing(°C)	27.50	27 ± 2	

Section In-Charge (Q.C)

HOD (Q.C)